



Memo: Lancaster County IFB No. 500200402
From: Cathy McDaniel, Procurement Director
Subject: Addendum No. 2
Date: March 30, 2020

The inquiry period for the above listed IFB closed at 12:00 AM on Thursday, March 26, 2020. The following questions were answered during the inquiry period and were deemed relevant to the integrity of the RFP.

- Thermostats at all locations must be Commstat 3.
- Alarm must be wired and functional upon completion.
- Only 1 unit will be replaced at the Pleasant Hill location.
- Contractor must guarantee 6 month pricing.
- Execution may be staggered with half of the units installed in the Spring of 2020 and half in the fall of 2020
- Please price the Foxhole location separately. A NC license and permit will be required for this location since it is located in Mecklenburg County. Submittals will be allowed that exclude Foxhole for this reason.

Please note these changes and contact me at cdmcdaniel@lancastersc.net if you have any questions.

Best Regards,

A handwritten signature in black ink that reads "Cathy McDaniel".

Cathy McDaniel
Procurement Director